



कार्यालय सहायक अभियन्ता जन स्वा० अभि० विभाग, नगर उपखण्ड
दौसा


Address :- Near Sanskrit collage, Gupteswar Circle Dausa, Email ID - aecity.dau.phed@rajasthan.gov.in

क्रमांक:-SP-1

दिनांक:-03.06.2020

सुरक्षित जल प्रमाण पत्र

प्रमाणित किया जाता है कि केंद्रीय विद्यालय दौसा में स्वच्छ पेय जल सप्लाई किया जा रहा है जिसका परीक्षण जल रसायन प्रयोगशाला दौसा के द्वारा किया गया है जिसकी परीक्षण रिपोर्ट प्रमाण पत्र के साथ संलग्न है।


03/06/2020
(एच०पी०मी०)

सहायक अभियन्ता
जन स्वा० अभि० विभाग
नगर उपखण्ड दौसा


प्राचार्य/Principal
केंद्रीय विद्यालय दौसा
Kendriya Vidyalaya, Dausa
(Dist.) 303303

OFFICE OF THE JUNIOR CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, DAUSA

REPORT OF THE CHEMICAL EXAMINATION OF WATER

No: Lab/Jr. Chem./Dausa/2020-21/ 47


Date 29.05.2020

To,
KENDRIYA VIDHYALAY
LALSOT ROAD,
DAUSA


Tehsil Dausa

Reference: Your Letter No. का.सं.2298-12/2000-21/श.वि.दी.सं. 12/21.05.2020

Particulars	Source	Tap	
	Location		
Block		Dausa	
Village/Town		Dausa	
Date of Collection		22.05.2020	
Date of receipt		22.05.2020	
Date of Examination		26.05.2020	
Private Chemical Sample No.		P-1	
	Permission value as per I.S.:10500/2012		
	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	
1. pH	6.5-8.5	6.5-8.5	7.7
2. Turbidity (NTU)	1	5	Nil
3. Colour (Hazen Units)	5	15	None
4. Odour	Un Objectionable		U.O.
5. Total Alkalinity (as CaCO ₃) mg/l	200	500	80
6. Total Hardness (as CaCO ₃) mg/l	200	600	120
7. Calcium Hardness			50
8. Calcium (as Ca) mg/l	75	200	20
9. Magnesium Hardness			70
10. Magnesium (as Mg) mg/l	30	100	17
11. Chloride (as Cl-) mg/l	250	1000	170
12. Nitrate (as NO ₃ -) mg/l	45	45	1
13. Sulphate (as SO ₄ -2) mg/l	200	400	2
14. Fluoride mg/l	1.0	1.5	0.92
15. Total Dissolve Solids mg/l	500	2000	440


 Junior Chemist
 P.H.E.D. Laboratory, Dausa

Date


 Junior Chemist
 P.H.E.D. Laboratory, Dausa

.. No: Lab/Jr. Chem./Dausa/2020-21/
Copy to:-
1. Chief Chemist, PHED Raj. Jaipur


 प्राचार्य/Principal
 केन्द्रीय विद्यालय दौसा
 Kendriya Vidyalaya, Dausa
 302303

W